



GENERAL HOG HOUSE WIRING RECOMMENDATIONS

1. USE No. 12 A.W.G. TYPE UF, NON-METALLIC SHEATHED CABLE WITH GROUND WIRE.
2. DO NOT USE MORE THAN 16 LAMPS (8 DOUBLE UNIT BROODERS) PER 20 AMPERE CIRCUIT.
3. USE ONLY GROUNDING TYPE DUPLEX CONVENIENCE OUTLETS.
4. REFLECTORS MUST BE FITTED WITH PORCELAIN RECEPTACLES WITHOUT SWITCHES WITH COVERED TERMINALS OR PIGTAILS CONNECTED TO OUTLET WITH No. 16, TYPE HSJ RUBBER COVERED CORD.
5. PERMANENT AND MOVABLE BUILDINGS MUST HAVE PROPERLY FUSED SERVICE ENTRANCE BOXES.
6. THESE RECOMMENDATIONS ARE SUBORDINATE TO LOCAL REGULATIONS.

RECOMMENDED INCANDESCENT LAMP SIZES

- MILD WEATHER..... 60 WATT
- COLD WEATHER..... 100 WATT
- VERY COLD WEATHER..... 150 WATT (MAX.)

CAUTION: DO NOT USE INFRARED LAMPS!

COÖPERATIVE EXTENSION WORK IN
 AGRICULTURE AND HOME ECONOMICS
 DEPARTMENT OF AGRICULTURAL ENGINEERING
 UNIVERSITY OF MARYLAND
 AND
 UNITED STATES DEPARTMENT OF AGRICULTURE COOPERATING

ELECTRIC BROODER FOR PIGS
 HOVER TYPE... FOR INCANDESCENT LAMPS

USDA '60 EX. 5907 SHEET 1 OF 1